

PENBERTHY

application report

Section 2000
Application Report 2775
Issued 05/05
Replaces 04/97

For: APPROVAL AND REGISTRATION AGENCIES

FM APPROVAL

Tyco Valves & Controls, L.P.
320 Locust Street
Prophetstown, IL 61277

Liquid Level Indicator. Model Series RL, RM, RMR, RH, RHR, RLC (Reflex) and TL, TM, TMR, TH, THR, TLC (Transparent). For applications not exceeding 250 psi (1720 kPa) at 400°F (204°C) or 450 psi (3100 kPa) at 100°F (38°C).

as listed in the current FMRC APPROVAL GUIDE - Flammable Liquid Equipment

CANADIAN REGISTRATION NUMBER

Models comply with all requirements of the ANSI & ASME codes as to their dimensions, material, identification & service for which they are required and are registered as

CRN
OF0990.9C